



കേരള സർക്കാർ

SANITARY FITNESS CERTIFICATE

No. 03/2023-24

Certified that I have inspected Mary Matha English School Pilathara. Pilathara (po) Kannur (Dist) PIN 670504. Cheruthazham Grama panchayath Building No. VI/485,486,487 A,B,C,D in RS. NO. 197/108 . The building and its sanitary arrangements made at present are satisfactory. Drinking water facility and its source are hygienic. Hence certificate is issued to run the above Establishment subjected to the conditions laid down in the Kerala Public Health Ordinance – 2022. I recommend for issuing the running license, for the purpose for the Year 2023-2024. This certificate is issued only for the above purpose.

The Certificate is valid up to 31/3/2024

Any Violation of the terms and conditions of the ordinance will automatically invalid this certificate and are liable to prosecution.

Place: Cheruthazham

Date: 15.06.2023



[Signature]
HEALTH INSPECTOR
HEALTHY HEALTH CENTRE
CHERUTHAZHAM P.O. PILATHARA
PIN 670504

[Signature]
MANAGER
Mary Matha English School
P.O. Pilathara - 670 504
Kannur Dt. Ph: 0497 2802010
No. CBSE/Aff./930657



KERALA WATER AUTHORITY
QUALITY CONTROL SUB DISTRICT LABORATORY, PAYYANNUR
WATER ANALYSIS REPORT



Tele phone No : 04985290734

email : kwaqualitysdipayyannur@gmail.com

TC-10906

ULR-TC109062300002575F

Report No - KWA/QA/R/06/2575/1/15/2763

Date : 15/06/2023

Customer Name and Address

MARY MATHA ENGLISH SCHOOL
PILATHARA
(P O) PILATHARA - 670 504
Forwarded by Health Inspector
F H C Cheruthazham
(NON DOMESTIC PURPOSES)

1. Date of receipt

:12/06/2023

2. Sampling provided by

: Customer(QUA_69448)

3. Sample Code

: 02/23 (1104) (Sealed)

4. Source of Sample

: Bore Well

5. Sample quantity

: 1 lit

6. Test performing dates

From : 12/06/2023

To : 12/06/2023

Sl No	Characteristics	Unit	Test Method	Acceptable limits as per IS 10500-2012	Result
1	Colour	HAZEN	IS 3025 (part 04) -1983 (Reaffirmed 2017)	5	-
2	Odour		IS 3025 (part 5) -2018	Agreeable	-
3	Turbidity	(NTU)	IS 3025 (part 10) -1984 (Reaffirmed 2017)	1	6.11
4	pH		IS 3025 (part 11) -1983 (Reaffirmed 2017)	6.5 to 8.5	7.95
5	Total Alkalinity (as CaCO ₃)	(mg/litre)	IS 3025 (part 23) -1986 (Reaffirmed 2019)	200	-
6	Total Dissolved Solids (TDS)	(mg/litre)	IS 3025 (part 16) -1984 (Reaffirmed 2017)	500	-
7	Total Hardness (as CaCO ₃)	(mg/litre)	IS 3025 (part 21) -2009 (Reaffirmed 2019)	200	25.74
8	Calcium (as Ca)	(mg/litre)	IS 3025 (part 40) -1991 (Reaffirmed 2019)	75	-
9	Magnesium (as Mg)	(mg/litre)	IS 3025 (part 46) -1994 (Reaffirmed 2019)	30	-
10	Chloride (as Cl)	(mg/litre)	IS 3025 (part 32) -1988 (Reaffirmed 2019)	250	9.84

Remarks:

The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the laboratory

*BDL : Below Detection Limit

Authorised By

Don
DEPUTY QUALITY MANAGER
QUALITY CONTROL SUBDISTRICT LAB PAYYANUR
KERALA WATER AUTHORITY PAYYANNUR
KANNUR DISTRICT

* End Of Report *

KWA/QC/SDL/PNR/R/17

Issue No: 01

Issue Date : 01.12.2021

Rev No: 00

Rev Date:00



Page 1 of 2

Don
MANAGER
Mary Matha English School
P.O. Pilathara - 670 504
Kannur Dt. Ph: 0497 2802010
No. CBSE/Atf./930657



**KERALA WATER AUTHORITY
QUALITY CONTROL SUB DISTRICT LABORATORY, PAYYANNUR
WATER ANALYSIS REPORT**

Tele phone No : 04985290734

email : kvaqualitysdlpayyannur@gmail.com

Report No - KWA/QA/R/06/2575/1/15/2763

Customer Name and Address	1. Date of receipt	Date : 15/06/2023
MARY MATHA ENGLISH SCHOOL PILATHARA (P O) PILATHARA - 670 504 Forwarded by Health Inspector F H C Cheruthazham (NON DOMESTIC PURPOSES)	2. Sampling provided by	: 12/06/2023
	3. Sample Code	: Customer(QUA_69440)
	4. Source of Sample	: 02/23 (1104) (Sealed)
	5. Sample quantity	: Bore Well
	6. Test performing dates	: 1 lit
		From : 12/06/2023

Sl No	Characteristics	Unit	Test Method	Acceptable limits as per IS 10500-2012	Result
1	Electrical Conductivity at 25°C	(micro mhos/cm)	IS 3025 (part 14) -2013 (Reaffirmed 2019)		105.10
2	Acidity	(mg/litre)	IS 3025 (part 22) -1986 (Reaffirmed 2019)		-
3	Sulphate (as SO ₄)	(mg/litre)	APHA23rd Edition (Turbidimetric method)	200	-
4	Fluoride (as F)	(mg/litre)	IS 3025 (part 60) -2009 (Reaffirmed 2013)	1	-
5	Iron (as Fe)	(mg/litre)	IS 3025 (part 53) -2003 (Reaffirmed 2014)	1	0.80
6	Nitrate (as NO ₃)	(mg/litre)	APHA23rd Edition (UV Screening method)	45	4.00
7	Residual Chlorine	(mg/litre)	IS 3025 (part 26)- 2021	0.2	-

Remarks:

The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the laboratory

*BDL : Below Detection Limit

Authorised By

* End Of Report *

Deputy Quality Manager
DEPUTY QUALITY MANAGER
 QUALITY CONTROL SUBDISTRICT LAB PAYYANNUR
 KERALA WATER AUTHORITY PAYYANNUR
 KANNUR DISTRICT
 Rev No: 00 Rev Date: 00

KWA/QC/SDL/PNR/R/17



Issue No: 01 Issue Date : 01.12.2021

MANAGER
 Quality Control Sub-District Laboratory
 Pilathara - 670 504
 Kannur Dt. Ph: 0497 280210
 No. CBSE/AF/930857



KERALA WATER AUTHORITY
QUALITY CONTROL SUB DISTRICT LABORATORY, PAYYANNUR
WATER ANALYSIS REPORT

Tele phone No : 04985290734
email : kwaqualitysdlpayyannur@gmail.com

Report No - KWA/QA/R/06/2575/R/1/83(1091)		Date : 15/06/2023			
Customer Name and Address		1. Date of receipt		:12/06/2023	
MARY MATHA ENGLISH SCHOOL PILATHARA (P O) PILATHARA - 670 504 Forwarded by Health Inspector F H C Cheruthazham (NON DOMESTIC PURPOSES)		2. Sampling provided by		: Customer(QUA_69448)	
		3. Sample Code		: 02/23 (1104) (Sealed)	
		4. Source of Sample		: Bore Well	
		5. Sample quantity		: 100ml	
		6. Test performing dates		From: 12/06/2023 To: 13/06/2023	
		SI No	Characteristics	Unit	Test Method
1	Total Coliforms	CFU /100 ml	IS 15185:2016;ISO 93081:2014	Nil	153
2	E.Coli	CFU /100 ml	IS 15185:2016;ISO 93081:2014	Nil	Nil

Remarks:

The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the laboratory

Authorised By

Bacteriologist

BACTERIOLOGIST

QUALITY CONTROL SUBDISTRICT LAB PAYYANNUR
KERALA WATER AUTHORITY
PAYYANNUR - 670 307

* End Of Report*

KWA/QC/SDL/PNR/R/17

Issue No: 01 Issue Date : 01.12.2021



MANAGER
Mary Matha English School
P.O. Pilathara - 670 504
Kannur Dt. Ph: 0497 2802010
No. CBSE/Atf /930657